


SLIP TEST RESULTS

Antislip Tape Yellow



35
years




Sliptest Victoria Pty Ltd
Accreditation Number 19858
3 Trebourn Ct, Rowville, 3178, VIC, Rowville, VIC, 3178
gary@sliptest.com.au
1300 SLIPTEST (1300 754 783)

Advance Antislip Surfaces PTY LTD - Yellow Antislip Tape



01 Jun 2024




Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Accredited for Compliance with ISO/IEC 17025 - Testing - Accreditation Number 19858

Date Tested:	01 Jun 2024
Test Report Number:	0106242
Client Name & Address:	Advance Antislip Surfaces PTY LTD - 6 A Aristoc Road Glen Waverley VIC 3150
Test Tile / Project :	Advance Antislip Tape
Surface / Product Tested :	Yellow Antislip Tape
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	15
Fixed / Unfixed Test :	Yes - Tested in the Direction of Anticipated Pedestrian Traffic
Testing Officer :	Gary Wiltshire
Testing Officer Signature	

Test Results :

	Mean BPN of last 3 swings :	Image of Surface
Specimen 1	81	
Specimen 2	79	

	Mean BPN of last 3 swings :	Image of Surface
Specimen 3	79	
Specimen 4	74	
Specimen 5	78	

Mean BPN Slip Resistance Value (SRV)

78

Using Slider 96 (4S) you have achieved a BPN of P5 => 54

Accredited for Compliance with ISO/IEC 17025 - Testing The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results to not account for Future Wear, Maintenance or Contamination of this surface once in-situ. Customer is responsible for the accuracy, completeness and regulatory compliance of all information about products provided to Sliptest Victoria PTY LTD pursuant to this test report.

Page 1 of 1 - END OF REPORT.

